

IMPORTANT SAFETY INSTRUCTIONS - SAVE THESE INSTRUCTIONS

Installation instructions for KREON - ERUBO on-Track, gear inclusive

! WARNING: READ AND UNDERSTAND ALL INSTRUCTIONS BEFORE STARTING INSTALLATION. SAVE THESE INSTRUCTIONS FOR FUTURE REFERENCE


! RISK OF FIRE! - RISK OF SHOCK!

- INSTRUCTIONS PERTAINING TO A RISK OF FIRE OR INJURY TO PERSONS - THIS LUMINAIRE MUST BE INSTALLED TO CONFIRM WITH NEC AND ALL LOCAL ELECTRICAL & BUILDING CODES & PRACTICES. TO ASSURE FULL COMPLIANCE WITH LOCAL CODES AND REGULATIONS, CONSULT WITH YOUR LOCAL

ELECTRICAL INSPECTOR BEFORE INSTALLATION.
- FOR USE WITH EUTRAC 230 2~TRACK SYSTEM ONLY
- CAUTION - TO REDUCE RISK OF A BURN DURING RELAMPING, REMOVE FROM THE TRACK BEFORE RELAMPING
- DISCONNECT POWERSUPPLY BEFORE INSTALLING OR SERVICING
- DO NOT ATTEMPT TO ENERGIZE ANYTHING OTHER THAN LIGHTING TRACK FIXTURES ON THE TRACK.
- TO REDUCE THE RISK OF FIRE AND ELECTRIC SHOCK, DO NOT ATTEMPT TO CONNECT POWER TOOLS, EXTENSION CORDS, APPLIANCES, AND THE LIKE TO THE TRACK.

WARNING
to reduce the risk of FIRE OR INJURY:
- turn off power and allow to cool before

replacing lamp
- lamp gets HOT quickly! contact only switch/plug when turning on
- do not touch hot lens, guard, reflector or enclosure
- keep lamp away from materials that may burn
- do not touch lamp at any time; use soft cloth; oil from skin may damage the lamp
- do not operate the luminaire with a missing or damaged shield, if required


 = CAUTION - RISK OF FIRE - do not install a lamp identified for use only in enclosed luminaires



 = grounding conductor

 = suitable for dry locations only

The luminaire can only be used with Kreon accessories.

This installation manual might not cover all details or variations. When additional information is required, please contact your local representative, or one of the Kreon offices.

 min.20" = do not install any luminaire closer than 20" from wall

 -  = a damaged safety glass must be replaced

1 notifications

Notice de montage pour KREON - ERUBO on-Track, auxiliaire inclus

! ATTENTION: LIRE ET COMPRENDRE TOUTES LES INSTRUCTIONS AVANT L'INSTALLATION CONSERVER CES INSTRUCTIONS POUR DE FUTURES REFERENCES

! RISQUE D'INCENDIE! RISQUE DE CHOC!


- INSTRUCTIONS RELATIVES À UN RISQUE D'INCENDIE OU DE BLESSURE
- CE PRODUIT DOIT ETRE INSTALLE SELON LE CODE D'INSTALLATION PERTINENT, PAR UNE PERSONNE QUI CONNAIT BIEN LE PRODUIT ET SON FONCTIONNEMENT AINSI QUE LES RISQUES INHERENTS
- CONSULTER UN ELECTRICIEN QUALIFIE POUR VOUS ASSURER QUE LES CONDUCTEURS DE LA DERIVATION SONT ADEQUATS


- UTILISATION SEULEMENT AVEC EUTRAC 230 2~SYSTEME DE RAIL
- CAUTION - POUR REDUIRE LE RISQUE, SUPPRIMER DU RAIL AVANT REMPLACER L'AMPOULE
- COUPER L'ALIMENTATION AVANT L'ENTRETIEN
- POUR REDUIRE LE RISQUE D'INCENDIE ET DE CHOC, N'UTILIZE PAS DES AUTRES OUTIL ELECTRIQUES SUR LE RAIL


ALERTE
pour réduire le risque D'INCENDIE OU DE BLESSURE:

- coupez l'alimentation électrique et laissez refroidir avant de remplacer l'ampoule
- la lampe chauffe rapidement!
- ne touchez pas l'objectif à chaud, la garde, le réflecteur ou une enceinte
- gardez le luminaire loin de matériaux qui peut brûler
- ne jamais touchez l'ampoule; utilisez un

chiffon doux; l'huile de la peau peut endommager l'ampoule
- luminaires équipés avec un verre de sécurité doivent operer d'un verre de sécurité complet et en place


 = ATTENTION - RISQUE D'INCENDIE - ne pas utiliser une ampoule conçue seulement pour des luminaires fermés



 = terre

 = pour emplacements secs seulement









Le luminaire ne peut être utilisé qu'avec des accessoires de Kreon.

Cette notice de montage ne couvre pas tous les détails ou les variations. Pour des informations supplémentaires veuillez contacter votre représentant local ou un des bureaux Kreon.

 min.20" = installer à au moins 20" du mur



 -  = un verre de sécurité endommagé doit être remplacé

1 notifications

technics		erubo on-track					<table><tr><th>Name</th><th>Reference</th><th>L x H x Ø</th><th>max. W</th><th>Voltage ↴</th></tr><tr><td>Erubo ⚡</td><td>ku92761_</td><td>6" x 117/8" x 31/8"</td><td>65W</td><td>120 V / 12 V</td></tr><tr><td>Erubo ⚡</td><td>kx92761_</td><td>6" x 117/8" x 31/8"</td><td>65W</td><td>277 V / 12 V</td></tr></table>	Name	Reference	L x H x Ø	max. W	Voltage ↴	Erubo ⚡	ku92761_	6" x 117/8" x 31/8"	65W	120 V / 12 V	Erubo ⚡	kx92761_	6" x 117/8" x 31/8"	65W	277 V / 12 V
Name	Reference	L x H x Ø	max. W	Voltage ↴																		
Erubo ⚡	ku92761_	6" x 117/8" x 31/8"	65W	120 V / 12 V																		
Erubo ⚡	kx92761_	6" x 117/8" x 31/8"	65W	277 V / 12 V																		
2 dimensions																						
3 installation		provide tracksystem, max. 2 circuits 120V or 277V to be used with EUTRAC® 2~ track system only disconnect powersupply while installing or servicing																				
4 installation		 <p>pull luminaire from the connector and rotate 90°</p>  <p>choose correct circuit on the 2~ connector</p>  <p>insert Erubo in track and make connection</p>																				
5 installation		 <p>pull luminaire and rotate in preferred direction</p> 																				




technics

Erubo on-Track



6 aim spotlight

aim spotlight manually
caution: lamp can be hot!



7 accessories

remove louvre

place lamp and reflector

place accessory in louvre



8 pictures

kreon nv

Industrieweg Noord 1152
B 3660 Opglabbeek, Belgium

Tel + 32-89-81 97 80
Fax + 32-89-81 97 90

www.kreon.com
mailbox@kreon.be

Rev. date: 01/09/2009
KR8276101677